IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 (X) MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 109443 PIN# 4775-14-7731 DATE 12-31-02

OWNER OR CONTRACTOR TERRATEK INC PHONE: Business 704-902-0119 Home 704-878-6633

ADDRESS 630 SIGNAL DRIVE EXT. STATESVILLE NC 28625

LOCATION 64 EAST (L) SAIN RD, (L) SPRING FORREST DRIVE, (L) HOWARDS POND, (R) DUCHENE AT LOT # 46

SUBDIVISION SPRING FORREST BLOCK / SECTION ____ LOT 46 LOT AREA .6680 AC SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .25

Septic Tank: 1000 Gallons; STB 1012 Date 3-20-03
Pump Tank: ____ Gallons; PT ____ Date ____
Pump Make: ____ Model ____ Serial No. ____
Nitrification Field: No Fields 1 Square Feet EQ=1920' Linear Feet 480'
No Lines 10 Trench Width 36" (MIN) Trench Bottom Depth 30" Gravel Depth N/A


(X) New System ☐ Repair System Type: I, II, (III), IV, V, VI
System Description: GRAV 25% REDUCTION
Repair System Description: LP PANEL
Maintenance Agreement Required: ☐ Yes (X) No


(X) House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Bathrooms 2½
☐ Business No. Employees ____
☐ Other ____
☐ Slab (X) Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual (X) Public ☐ Community

Comments/Conditions: (*) (1) MINIMUM TRENCH BOTTOM DEPTH IS 30". IT MAY BE DEEPER THAN 30" IF DESIRED.

Comments/Conditions: (2) MAINTAIN SETBACKS & INSTALL LINES ON CONTOURS (3) THE REGIONAL SOIL SCIENTIST, Gene Young from NLDENR, VISITED THE SITE & GAVE THE L.T.A.R (4) NOTE TRENCH BOTTOM DEPTH





Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: ____ date 12-31-02 Installed by: DAVID YOUNTZ

Improvement Permit by: ____ date 12-31-02 Operation Permit by: STEVE HEDRICK date 6/25/2003

Authorization to Construct by: ____ date 12-31-02 Existing System Inspection by: ____ date ____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK