DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of
PROPERTY ID #: 104115
COUNTY: 4775-15-7401

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: TERRATEK
ADDRESS:
PROPOSED FACILITY:
LOCATION OF SITE: SPRING FOREST Subd LOT 71
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

APPLICANT:
APPLICATION DATE: DATE EVALUATED:
PROPOSED DESIGN FLOW (.1949): PROPERTY SIZE:
PROPERTY RECORDED:

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	8% L	0-8"	scl wk gr	fr, NS, np, vscp		>48"			PS
		8-32"	C med sbk	fr/fi, SS, SP, scp					1.3
		32-48"	C scp inclusions	fr, SS, sp, scp					
2	8% L	0-8"	scl wk gr	fr, ns, np, vscp		>48"			PS
		8-32"	C med sbk	fr, SS, SP, scp					1.3
		32-48"	C scp inclus	fr, SS, SP, scp					
3	14% EDGE OF DRAINAGE	0-8"	scl wk gr sbk	fr, ns, np, vscp					PS
		8-36"	C, med, sbk	fi, S, P, scp	1.5BG BROWN mottles 24"				
		36-48"	C, med, sbk	fi/fr, S, P, scp	BG mottles mixed in				.2
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	ECW 154.000	GRAV/Pump & Haul
Site LTAR	.3	.2 - BANK

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY:
OTHER(S) PRESENT: