IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Charles Hauser DATE 12-21-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E TR on New Salem Ch. Rd 2314 TL on Parks Rd Past church Take Rd at end 1st house on left. S. R. No. _____


SUBDIVISION NAME Eastwood Acres LOT NO. 8+7 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil clay	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	80 min/inch	
Auto. Wash. Machine	Yes ( )	No (✓)	Topography	2 to 6% Slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+	
			Rock or other impervious formations	None	

Lot Area 160 x 200



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 780 Linear Ft. 260
Depth of Stone in Lines 16 to 18"
Water Supply: Individual ( )
Public (✓)

Installed by Jackey Const. Co.

IMPROVEMENTS PERMIT BY Andrew Causey

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 12-21-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold