IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Eddie N. Nicholson DATE 11-15-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E TR on Rd 2314 - TL in 1/2 pond Rt.

SUBDIVISION NAME Eastwood Acres LOT NO. 4 - S. HALF S. R. No. _____

SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other Rent. Available

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 3/4 Acres

Character & Porosity of Soil Red Clay
Percolation Rate Good
Topography 2 - 6% Slope
Depth to Water Table Deep
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Sam Outwalt

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 11/15/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold