IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Don West DATE 12-28-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 6 d E. T + on Rd # 2177

_____ S. R. No. _____


SUBDIVISION NAME Fox Creek LOT NO. 45 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	2 min
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6-10% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4 ft
			Rock or other impervious formations	None

Lot Area 2 acres



Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 150 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Fox Jr. DATE 12/28/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold