IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Melvin Bass DATE 9-30-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E on TL on Rd #2177

S. R. No. _____


SUBDIVISION NAME Fox Creek LOT NO. 3 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Med
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6% slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	deep
			Rock or other impervious formations	None

Lot Area _____



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft 300
Depth of Stone in Lines 18"

Water Supply: Individual ( )
Public (✓)

Installed by Eddie Young & Son

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 9/30/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold