IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Melvin Barr DATE 5-18-77 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION 64 E. TL on Rd # 2177 -

SUBDIVISION NAME Fox Creek LOT NO. 2 SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	GR B 3
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	fast
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6-10% slope to front
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	25+
Lot Area	1 Acre 245 x 145		Rock or other impervious formations	none



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Eddie Truesdale & Son

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steven Fox DATE 5/18/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold