IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Steve Hill DATE 7-28-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E TL on Rt 2177

S. R. No. 2177


SUBDIVISION NAME Salem Park LOT NO. 33 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	CfB2
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Mod
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2% to 4% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10+
			Rock or other impervious formations	None

Lot Area 100X200



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (✓)

Installed by Henry Sigmon

IMPROVEMENTS PERMIT BY Glenn Fox

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 7-28-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold