IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Donald Champion DATE 6-21-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E TL on new Salem ch Rd Turn right into Foxcreek at circle TL 1000' on left. S. R. No. _____

SUBDIVISION NAME Foxcreek LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 1 acre+

Character & Porosity of Soil Cecil gravely Clay
Percolation Rate 60 min/inch
Topography 2 to 4% slope
Depth to Water Table 10'+
Rock or other impervious formations Hard rock formations 5' down, rock in first 20' of ditch.



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 770 Linear Ft. 220
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Harlee Lackey

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Hit rock on system so lay-out was Changed. Had to dig with front end loader. bottom & sides of ditch were scratched to compensate for packing by machine.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 6-21-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold