IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gaye Chapel Church DATE 10-22-82 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E. TR on SR 2305 - TR 1st paved Road to Right - Church at end of Rd


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____ S. R. No. _____

House ( ) Mobile Home ( ) Business ( ) Other Addition to 110 Member Church Bathrooms + Fellowship Hall

No. Bedrooms _____ No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Appling Clay
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	.5 gal Sq ft Appl.
Auto. Wash. Machine	Yes (X)	No (X)	Topography	2-6%
Site Suitable	Yes ( )	No ( )	Depth to Water Table	10' +
Lot Area ACREAGE			Rock or other impervious formations	NONE

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by Robert Hoke

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Fox Jr DATE 10/22/82

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold