DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Sharon Welborn APPLICANT: Same
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 5/18/01
PROPOSED FACILITY: 3BR Modular PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 2.0
LOCATION OF SITE: ___ PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

(page 1 of 2)

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	7% Linear	0-6	sl g	NS NP VFR					PS .25
		6-29	scl	SS SP SFR					
		29-48	sl w/sap some mica		Chroma 3				
2	3% Linear	0-7	sl g	NS NP VFR					US Soil Wetness
		7-36	scl w/sap	SS SP SFR	28" Chroma 2				
3	3% Linear	0-8	sl g						US
		8-34	scl w/sap	VFR SS SP SFR	21" Chroma 2				
4	5% Linear	0-2	sl g	VFR NS NP VFR					PS .35
		2-19	sl sap	FI SP SFR					
		19-34	scl w/sap sap	FR S SP SFR					
		34-48	sap (w) s	NS NP VFR					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Perm, Conven	Perm, Soil Rep
Site LTAR	.35	.25

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: ___