DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

# SOIL/SITE EVALUATION
## *for* ON-SITE WASTEWATER SYSTEM

OWNER: Sharon Welborn APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 5/18/0
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: 2+
LOCATION OF SITE: ___ PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

(Page 2 of 2)

| PROFILE # | .1940 LANDSCAPE POSITION/ SLOPE % | HORIZON DEPTH (IN.) | SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE | SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY | OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR | .1943 SOIL DEPTH | .1956 SAPRO CLASS | .1944 RESTR HORIZ | PROFIL. CLASS & LTAR |
|---|---|---|---|---|---|---|---|---|---|
| X 5 | open field 7% Linear | 0-2 | SL (S) | NS NP NE xp | | | | | PS .35 |
| | | 2-10 | cSL SbK | Fi SP SE xp | | | | | |
| | | 10-24 | cSL/SCL/SbK | Fr SS SE xp | | | | | |
| | | 24-48 | SCL (S) 15 | (S) NS NP NE xp | | | | | |
| 6 | Woods 7% Linear | 0-6 | SL (S) | vfr NS NP NE xp | | | | | PS .35 |
| | | 6-12 | cL SbK | Fi S P SE xp | | | | | |
| | | 12-36 | CL/SCL/SiCL | fr SS SP SE xp | | | | | |
| | | 36-49 | SCL (S) SL | (S) NS NP NE xp | | | | | |
| 3 | | | | | | | | | |
| 4 | | | | | | | | | |

| DESCRIPTION | INITIAL SYSTEM | REPAIR SYSTEM |
|---|---|---|
| Available Space (.1945) | | |
| System Type(s) | | |
| Site LTAR | | |

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___