IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Melvin Ban Deaning DATE 6/16/78 PERMIT NO. _____

PHONE Business _____ Home _____

LOCATION 64. E Tl. on Rd # 2177 to Fox Creek


S. R. No. _____

SUBDIVISION NAME Fox Creek LOT NO. 11 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2
Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 1.01

Character & Porosity of Soil C & Br
Percolation Rate _____
Topography 6-10% Slope
Depth to Water Table Low
Rock or other impervious formations Some near end of ditch



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Eddie Jounty & Son

IMPROVEMENTS PERMIT BY Glen Fox Jr

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 6/16/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold