DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PAGE 2

Sheet ___ of ___
PROPERTY ID #: ____
COUNTY: ____
103659
4775-64-1937

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: SHONSTROUD / TERRY WALLER APPLICANT: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: ____
PROPOSED FACILITY: ____ PROPOSED DESIGN FLOW (.1949): ____ PROPERTY SIZE: ____
LOCATION OF SITE: ____ PROPERTY RECORDED: ____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
5 @		0-38"	C, med, sbk		Chroma 2 48"				PS .25
		38"	C sap incl, sbk						
		38"-48"	C sap incl sbk magnese stains						
6 @			HEAVY CLAY THROUGHOUT SIDEWALL INFILTRATION OF MAGENESE STAINS EXTENSIVE THROUGHOUT ENTIRE DEPTH OF TRENCH		H2O				US
7 @		0-34"	C sap incl		..US AT 34" BELOW DRAINFIELD AREA				US
		34-60"	C1 sap						
8 @									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	PUMP 25% RED	LP PIPE
Site LTAR	.25	.15

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: L. COOK, B. FREEMAN
OTHER(S) PRESENT: TERRY WALLER, SHONSTROUD, HIS FRIEND ANDY CRAWFORD