DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 2
PROPERTY ID #:
COUNTY: 49

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: JENNIFER HURT
ADDRESS: 130 OAK FOREST DR, STATESVILLE
PROPOSED FACILITY: RESIDENCE PROPOSED DESIGN FLOW (.1949): 120 GPD
LOCATION OF SITE: 130 OAK FOREST DR STATESVILLE
WATER SUPPLY: • Private • (Public) • Well • Spring • Other
EVALUATION METHOD: • (Auger Boring) • Pit • Cut

APPLICATION DATE 9/3/13
DATE EVALUATED: 9/23/13
PROPERTY SIZE:
PROPERTY RECORDED:
TYPE OF WASTEWATER: • (Sewage) • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 7%	0-3	CL SBK	wf SS/SP	14" mottle 10YR 7/8				.3
		4-48	C SBK	mm SS/SP					
2	L 6%	0-7	CL SBK	wf SS/SP	10YR 8/8 @ 16"		10YR 7/1 @ 22		.3
		8-48	C SBK	mm SS/SP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	CON. GRAVITY	→ SAME
System Type(s)	II	II
Site LTAR	.3	.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: KIM MCMURRE, REHS
OTHER(S) PRESENT: PROPERTY OWNER

COMMENTS: