IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Coyet Wyatt DATE 3-27-92 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64E TR Barry oak TL oak Forest 3rt Hse on left. S.R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ☐ Mobile Home ☐ Business ☐ Other Repair

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit Yes ☐ No ☐

Auto. Dishwasher Yes ☐ No ☐

Auto. Wash. Machine Yes ☐ No ☐

Lot Area _____

Soil Characteristics Clayey


Application Rate .3

Topography 2 to 6 %

Depth to Water Table 10'+

Rock or other impervious formations none

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement _____ Crawl Space



Plot of System (Not to Scale)

Size of Tank Ex Gals.

Nitrification Field:

No. of Lines 1

Sq. Ft. 300 Linear Ft. 100

Depth of Stone in Lines 12"

Water Supply: Individual ☑ Public ☐

Installed by Donald Zachry

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY L. C. Moore

COMMENTS _____

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 3-27-92

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold