IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hayden Hanby DATE 7-19-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E. 1st Newman Rd past Rd # 2303

S. R. No. 64 E


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Good	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to Front	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	24	
			Rock or other impervious formations	None	

Lot Area 200 x 250



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Iredell County Health Dept

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 7/19/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold