## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

~~OWNER~~ OR CONTRACTOR John Fox. Douglas C. Barnette DATE 1-10-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E. on Rt after you pass J+S Service Sta

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

| | | | |
|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) |
| Auto. Dishwasher | Yes (✓) | No ( ) |
| Auto. Wash. Machine | Yes (✓) | No ( ) |
| Site Suitable | Yes (✓) | No ( ) |

Lot Area 1 ACRE

Character & Porosity of Soil Red Clay
Percolation Rate same
Topography slope to front
Depth to Water Table same
Rock or other impervious formations —




Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 240
Depth of Stone in Lines _____
Water Supply: Individual ( )
Public (✓)
Chelsea Water Corp
Installed by Harry Ray

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Fox Jr DATE 1-10-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold