DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: William PARKER APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: 337 BARRY OAK RD PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed GRADE OUT TERRACE'S

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1		0-6	scl, wk, gr	fr ns, np, ncep		≥ 32"	PS		PS .3
		6-32"	c, med, sbk	fr/fi; ss, sp; scep					
		32-48"	loamy sap	fr ns np ncep					
2		0-6"	scl, wk, gr	fr, ns, np, ncep		≥ 36	PS		PS .3
		6-36"	c, med, sbk	fr, ss, sp, scep					
		36-48"	loamy sap	fr, ns, np, ncep					
3		0-6"	scl, wk, gr	fr, ns, np, ncep	tiger dirt > crom 2 mottles 6"-36"	≥ 36	PS		PS .25
		6-36"	c, med, sbk	fi, s, p, scep					
		36-48"	sl sap mix	fr, ns np ncep					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	CONV GRAV	SAME
Site LTAR	.5	.5

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): IS
EVALUATED BY: L. COOK
OTHER(S) PRESENT: _____