DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: 4775-92-8198
COUNTY: Tiedell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Lawrence Marzone
ADDRESS: 107 Elmwood Rd
PROPOSED FACILITY: SFD
LOCATION OF SITE: 64 E to Barry Oak to Elmwood
WATER SUPPLY: • Private • Public • Well • Spring • Other
EVALUATION METHOD: • Auger Boring • Pit • Cut

APPLICATION DATE 4-21-14
DATE EVALUATED: 06/04/14
PROPOSED DESIGN FLOW (.1949): 360
PROPERTY SIZE: 1.76ac
PROPERTY RECORDED: Yes
TYPE OF WASTEWATER: • Sewage • Industrial Process • Mixed N/A

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 2%	0-12	Manp-		Chroma 4's 21"-36"	PS	N/A	N/A	PS .3
		12-60	C fi	ABK SE					
2	L 2%	0-12	Mand		Chroma 3&4's 20"-36"	PS	N/A	N/A	PS .3
		12-48	C fi						
		48-60	BC fi/lr	WABK SE					
3	L 2%	0-12	Scl fr	gr SE	Chroma 3'1+4S 20"-36"	PS	N/A	N/A	PS .3
		12-40	C fi	SBK SE					
		40-60	BC fi/lr	WABKSE					
4	L 2%	0-12	Scl fr	gr SE	Chroma 2S 3&4S 12"-48"	PS	N/A	N/A	UNS
		12-50	C fi	SBK SE					
		50-60	BC fi/lr	WABKSE					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	
System Type(s)	25%	
Site LTAR	.3	

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: H. Snow
OTHER(S) PRESENT: A. Pruitt

COMMENTS: