✓ a

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Nelson Brown DATE 10-1-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Pine Hill Heights - (Rd. 2166) -

S. R. No. _____

SUBDIVISION NAME Pine Hill Heights LOT NO. 8 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 15,000


Character & Porosity of Soil Red Clay

Percolation Rate _____

Topography Gently Sloping

Depth to Water Table _____

Rock or other impervious formations Granite



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3 - 2 -

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Community Water

Installed by Raymond Adams

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steven Todd Jones DATE 10/1/74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold