IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ronald mattox DATE 3-23-88 PERMIT NO.

PHONE: Business Home

LOCATION Lot 40 Independence Loop 2nd Sub. 2nd Hearth S. R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

Home (✓) Mobile Home ( ) Business ( ) Other


No. Bedrooms No. Bathrooms

Garbage Disposal Unit	Yes ( )	No ( )	
Auto. Dishwasher	Yes ( )	No ( )	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes ( )	No ( )	

Character & Porosity of Soil clayey
Percolation Rate .3
Topography rolling
Depth to Water Table pit
Rock or other impervious formations none

Lot Area

___ Basement with Plumbing ___ Basement without Plumbing ___ No Basement



Plot of System

Size of Tank Existing 1000 Gal.
Nitrification Field:
No. of Lines 2
Sq. Ft. 450 Linear Ft. 150
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)
+ 16 Ton Pit

Installed by Sammy Reavis

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY P. C. moore

COMMENTS:

CERTIFICATE OF COMPLETION BY P. C. moore DATE 3-24-88

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold