DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: _____
COUNTY _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Sourtsack Luangthen OWNER: _ AGENT: _ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
_____ PROPOSED FACILITY: _____
_____ PROPERTY SIZE: _____
LOCATION OF SITE: _____
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	Linear 6%	0 to 6	L	GR		.1942 WETNESS CONDITION -	PS
		6 to 24	C	SBK	SEAP	.1943/ 1956 SAPROLITE -	PS
		24 to 48	CL	WSBK	WEAP	.1944 RESTRICTIVE HORIZON -	PS
						.1948 PROFILE CLASSIFICATION -	PS
						PROFILE LTAR -	.32
2	Linear 10%	0 to 6	L	GR		.1942 WETNESS CONDITION -	PS
		6 to 24	C	SBK	SEAP	.1943/ 1956 SAPROLITE -	PS
		24 to 48	CL	WSBK	WEAP	.1944 RESTRICTIVE HORIZON -	PS
						.1948 PROFILE CLASSIFICATION -	PS
						PROFILE LTAR -	.33
3						.1942 WETNESS CONDITION -	
						.1943/ 1956 SAPROLITE -	
						.1944 RESTRICTIVE HORIZON -	
						.1948 PROFILE CLASSIFICATION -	
						PROFILE LTAR -	
4						.1942 WETNESS CONDITION -	
						.1943/ 1956 SAPROLITE -	
						.1944 RESTRICTIVE HORIZON -	
						.1948 PROFILE CLASSIFICATION -	
						PROFILE LTAR -	
5						.1942 WETNESS CONDITION -	
						.1943/ 1956 SAPROLITE -	
						.1944 RESTRICTIVE HORIZON -	
						.1948 PROFILE CLASSIFICATION -	
						PROFILE LTAR -	

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): _____ SITE LONG-TERM ACCEPTANCE RATE: .33
OTHER FACTORS(.1946) _____ SYSTEM TYPE _____
EVALUATED BY: E. Cimoore OTHER(S) PRESENT: _____
COMMENTS: _____

DRAFT