DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Jerry Campbell OWNER: ✓ AGENT: ___ PHONE: 878 9215
ADDRESS: 325 S. Race APPLICATION DATE: 6-8-93 DATE EVALUATED: 6-11-93
Statesville PROPOSED FACILITY: Single Family Dwelling
PROPERTY SIZE: 3.30 acres
LOCATION OF SITE: 64 E ~~I-40~~ to Riverhill Rd past Chestnut Grove Union rd
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	2 to 6% nose	0 to 2	Granular Scl		none	none	P.S.	36 to 46 Transition	.4
		2 to 22	Blocky C l	1:1 Firm					
		22 to 36	Blocky Scl	1:1 Friable					
2	2 to 4% linear to Head slope	0 to 4	Scl	1:1 very Firm	none	none	P.S.	40 to 46" Transition	.35
		2 to 38	C	1:1 Firm					
		38 to 46	Scl						
3									
4									
5									

AVAILABLE SPACE (.1945) ____ SITE CLASSIFICATION (.1948): ____ SITE LONG-TERM ACCEPTANCE RATE: ____

EVALUATED BY: ____ OTHER(S) PRESENT: ____

COMMENTS: ____