IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Lex White DATE 6-14-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E - Left on Rd # 2155 - Thru Left on Rd # 2182 3rd brick house on Left S. R. No. 2182

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 7 acres

Character & Porosity of Soil Red Clay
Percolation Rate _____
Topography Slight Rolling
Depth to Water Table _____
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines _____
Water Supply: Individual ( )
Public (✓)

Installed by Robt Turbyfill
(Henry Narroman)

IMPROVEMENTS PERMIT BY _____

COMMENTS: This House built a few years - installing bath -

CERTIFICATE OF COMPLETION BY Glenn Tate Jr. DATE 6/14/74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold