HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Bill Brewer OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	10% Linear	0 to 4"	L	GR		.1942 WETNES CONDITION	N/A
		4 to 24	C	SBK	1:1	.1943/.1956 SAPROLITE	24"
		24" +	weathered rock (Gap)			.1944 RESTRICTIVE HORIZON	weathered rock 24"
						.1948 PROFILE CLASSIFICATION	U
						PROFILE LTAR	
2	10% Linear	0 to 4"	L	GR		.1942 WETNES CONDITION	N/A
		4 to 22	C	SBK	1:1	.1943/.1956 SAPROLITE	22"
		22 +	Saprolite Weathered Rock			.1944 RESTRICTIVE HORIZON	Weathered Rock
						.1948 PROFILE CLASSIFICATION	U
						PROFILE LTAR	
3	8% Linear	0 to 4	L	GR		.1942 WETNESS CONDITION	N/A
		4 to 42	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		42 to 48	Transition			.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	135
4	8% Linear	0 to 4"	L	GR		.1942 WETNESS CONDITION	N/A
		4 to 38	C	SBK	1:1	.1943/.1956 SAPROLITE	42"
		38 to 42	Transition			.1944 RESTRICTIVE HORIZON	N/A
		42 +	Saprolite			.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	135
5	8% Linear	0 to 4"	L	GR		.1942 WETNESS CONDITION	N/A
		4 to 36	C	SBK	1:1	.1943/.1956 SAPROLITE	42"
		36 to 42	Transition			.1944 RESTRICTIVE HORIZON	PS
		42 to 48	Saprolite			.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	135

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE: 135
OTHER FACTORS(.1946): SYSTEM TYPE: Conv. Gravity
EVALUATED BY: J.C. Moore OTHER(S) PRESENT: Bill + Sandy Brewer
COMMENTS:

DRAFT