IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 96316 PIN# 4776 82 2184 DATE 9-10-98

OWNER OR CONTRACTOR Chris Davidson PHONE: Business 528 6192 Home

ADDRESS PO BOX 252 Troutman

LOCATION 64 E to Swann Rd across from McAllister Rd on Rt

SUBDIVISION D+D Enterprises BLOCK / SECTION LOT LOT AREA 1.82 acres SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. 1.3


Septic Tank: 1000 Gallons; STB 786 Date 7-31-98
Pump Tank: Gallons; PT Date
Pump Make: Model Serial No.
Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400
No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth 12"

☐ New System ☐ Repair System Type: I, II, III, IV, V, VI
System Description: Conv. Gravity
Repair System Description: Gravity 25% Red
Maintenance Agreement Required: ☐ Yes ☐ No


☐ House/Mod. Home No. Bedrooms 3
☐ Mobile Home No. Bathrooms 2
☐ Business No. Employees
☐ Other
☐ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☐ Public ☐ Community

Comments/Conditions:



Comments/Conditions:



I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Neil Hale date 9-14-98 Installed by: Chris Davidson

Improvement Permit by: J.C. Moore date 9-10-98 Operation Permit by: J.C. Moore date 1-28-99

Authorization to Construct by: J.C. Moore date 9-10-98 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD