IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mrs. Roy Lazenby DATE 12-15-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Old mocksville Rd Turn on Cool Springs Rd 3rd house on Rt. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Repair


No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	
Auto. Dishwasher	Yes ( )	No ( )	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes ( )	No ( )	

Character & Porosity of Soil Clayey
Percolation Rate 24
Topography 2+ to Ea
Depth to Water Table 10'+
Rock or other impervious formations None

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 1
Sq. Ft. 300 Linear Ft. 700
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by A&A Enterprises

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY L.C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L.C. Moore DATE 12-15-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold