HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Bradley Tomlin OWNER: AGENT: PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: ____
____ PROPOSED FACILITY: ____
____ PROPERTY SIZE: ____
LOCATION OF SITE: AT Intersection of Chief Thomas & Old Mocksville
WATER SUPPLY: On-Site Well ____ Comm. Well ____ Public ____ Other ____ EVAL. METHOD: Auger Boring ____ Pit ____ Cut ____

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	linear 10%	0 to 6	L	GR		.1942 WETNES CONDITION -	N/A
		6 to 35	C	ABK	1:1	.1943/.1956 SAPROLITE -	N/A
		35 to 48	C	weak ABK	1:1	.1944 RESTRICTIVE HORIZON -	N/A
						.1948 PROFILE CLASSIFICATION -	PS
						PROFILE LTAR -	.3
2	linear 10%	0 to 8	L	GR		.1942 WETNES CONDITION -	N/A
		8 to 32	C	ABK	1:1	.1943/.1956 SAPROLITE -	N/A
		32 to 48	C	weak ABK	1:1	.1944 RESTRICTIVE HORIZON -	N/A
						.1948 PROFILE CLASSIFICATION -	PS
						PROFILE LTAR -	.3
3						.1942 WETNESS CONDITION -	
						.1943/.1956 SAPROLITE -	
						.1944 RESTRICTIVE HORIZON -	
						.1948 PROFILE CLASSIFICATION -	
						PROFILE LTAR -	
4						.1942 WETNESS CONDITION -	
						.1943/.1956 SAPROLITE -	
						.1944 RESTRICTIVE HORIZON -	
						.1948 PROFILE CLASSIFICATION -	
						PROFILE LTAR -	
5						.1942 WETNESS CONDITION -	
						.1943/.1956 SAPROLITE -	
						.1944 RESTRICTIVE HORIZON -	
						.1948 PROFILE CLASSIFICATION -	
						PROFILE LTAR -	

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
OTHER FACTORS(.1946) ____ SYSTEM TYPE Conv. Gravity
EVALUATED BY: J.C. Moore OTHER(S) PRESENT: Kenneth McCann
COMMENTS: ____

DRAFT

002590