1905

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

DATE 10-3-90 PERMIT NO. 116-1-A-7

OWNER OR CONTRACTOR Ronald Dale west

PHONE: Business _____ Home _____

LOCATION White Oak Branch Rd S. R. No. _____

SUBDIVISION NAME Deer Park LOT NO. 17 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clayey

Percolation Rate 4 to 120

Topography Lot

Depth to Water Table _____

Rock or other impervious formations none

Lot Area 2.19 acres

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement

Size of Tank 1250 Gals.

Nitrification Field:


No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )



Plot of System

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: Keep well 100' From S.T. System

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 10-8-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold