DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Piedmont Housing OWNER: __ AGENT: __ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____
PROPERTY SIZE: _____
LOCATION OF SITE: Coolwood lot #5
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	Linear 6%	0 to 48	C SBK	SEAP Fi sticky / very sticky	PS	PS	PS	PS	.25
2	Linear 6%	0 to 48	C SBK	SEAP Fi	Chroma 4	PS	PS	PS	.2
3	Linear 6%	0 to 48	C SBK	SEAP Fi sticky	PS	PS	PS	PS	.3
4									
5									

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): _____ SITE LONG-TERM ACCEPTANCE RATE: .25
EVALUATED BY: Tidmoor OTHER(S) PRESENT: _____
COMMENTS: _____

0018112