DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET ____ OF ____
PROPERTY I.D.#: ____
DATE: ____
COUNTY: ____

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: J.C. moore
ADDRESS: ____
OWNER ___ AGENT: ___ PHONE: ____
APPLICATION DATE: ____ DATE EVALUATED ____
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: Lot 34 Coolwood
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	1940 LANDSCP POS / SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1		0 to 4	L					.1942 Wetness Cond. - N/A
		4 to 46	C	SBK	NEAP			.1943 Depth/.1956 Sapr. - N/A
	Linear 6%							.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - P3
								Profile LTAR - .3
2		0 to 4	L					.1942 Wetness Cond. - N/A
		4 to 34	C	SBK	NEAP			.1943 Depth/.1956 Sapr. - N/A
	Linear 6%	34 to 46	CL	WSBK	NEAP			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - P3
								Profile LTAR - .3
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) X OTHER FACTORS (.1946) ____ SITE CLASSIFICATION (.1948) P3
SYSTEM TYPE Conv. Gravity LONG-TERM ACCEPTANCE RATE(S) .3
EVALUATED BY: J.C. moore OTHER(S) PRESENT: Jim Barkley
COMMENTS: ____