HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I D # ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Sherman white OWNER: AGENT: PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: ____
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: [redacted] Cool Wood 56
WATER SUPPLY: On-Site Well___ Comm. Well___ Public___ Other___ EVAL. METHOD: Auger Boring___ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	linear 8%	0 to 8	L	Topsoil		1942 WETNES CONDITION	PS
		8 to 48	C	ABK	SEAP	1943/ 1956 SAPROLITE	PS
						1944 RESTRICTIVE HORIZON	PS
						1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.27
2	linear 8%	0 to 8	L	Topsoil		1942 WETNES CONDITION	PS
		8 to 48	C	ABK	SEAP	1943/ 1956 SAPROLITE	PS
						1944 RESTRICTIVE HORIZON	PS
						1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.27
3						1942 WETNESS CONDITION	
						1943/ 1956 SAPROLITE	
						1944 RESTRICTIVE HORIZON	
						1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
4						1942 WETNESS CONDITION	
						1943/ 1956 SAPROLITE	
						1944 RESTRICTIVE HORIZON	
						1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						1942 WETNESS CONDITION	
						1943/ 1956 SAPROLITE	
						1944 RESTRICTIVE HORIZON	
						1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): ____ SITE LONG-TERM ACCEPTANCE RATE .27
OTHER FACTORS(.1946): ____ SYSTEM TYPE ____
EVALUATED BY: ____ OTHER(S) PRESENT Maria White
COMMENTS ____

DRAFT

002177