DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES — DRAFT
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
DATE: ____
COUNTY: ____

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Daniel F Loomis — OWNER ___ AGENT: ___ PHONE: ____
ADDRESS: ____
APPLICATION DATE: ____ DATE EVALUATED ____
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: lot 26 Cool Wood
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	1940 LANDSCP POS / SLOPE(%)	HORIZON DEPTH (IN.)	1941 (1) TEXTURE	(2) STRUCTURE	(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	linear 8%	0 to 4	L	GR				.1942 Wetness Cond. - N/A
		4 to 30	C	SBK	NEAP			.1943 Depth/.1956 Sapr. - N/A
		30 to 46	SCL	weak SBK	NEAP			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .35
2	linear 8%	0 to 4	L	GR				.1942 Wetness Cond. - N/A
		4 to 28	C	SBK	NEAP			.1943 Depth/.1956 Sapr. - N/A
		28 to 48	SCL	weak SBK	NEAP			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .35
3	linear 12%	0 to 4	L	GR	N			.1942 Wetness Cond. - yes
		4 to 18	C	SBK	SEAP			.1943 Depth/.1956 Sapr. - N/A
		18 to 40	C	~~SBK~~	SEAP	10YR	6	.1944 Restrictive Hori. - N/A
		~~40 to 48~~	C	weak SBK	EAP	10YR	4	.1948 Profile Class. - PS
								Profile LTAR - .25
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

SUITABLE SPACE (.1945) ____ OTHER FACTORS (.1946) ____ SITE CLASSIFICATION (.1948) PS
SYSTEM TYPE Chamber — LONG-TERM ACCEPTANCE RATE(S) .35
EVALUATED BY: J.C. Moore — OTHER(S) PRESENT: Dan Loomis
COMMENTS: ____

0012411