DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET____ OF____

PROPERTY I.D.#:____

DATE:____

COUNTY:____

SOIL SITE EVALUATION FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Janet Forsythe OWNER__AGENT:__PHONE:____

ADDRESS:____ APPLICATION DATE:____ DATE EVALUATED____

PROPOSED FACILITY:____

PROPERTY SIZE:____

LOCATION OF SITE: Lot 23 Coolwood

WATER SUPPLY: On-site Well____ Comm. Well___ Public__ Other____ EVAL. METHOD: Auger Boring_/ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	linear 4%	0 to 6	L	GR				.1942 Wetness Cond. - N/A
		6 to 24	C	SBK	SEAP			.1943 Depth/.1956 Sapr. - N/A
		24+ to 48	CL	WSBK	NEAP			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .133
2	linear 9%	0 to 6	L	GR				.1942 Wetness Cond. - N/A
		6 to 24	C	SBK	SEAP			.1943 Depth/.1956 Sapr. - N/A
		24+ to 48	CL	SBK	SEAP			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .133
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) Yes OTHER FACTORS (.1946)____ SITECLASSIFICATION (.1948) PS

SYSTEM TYPE____ LONG-TERM ACCEPTANCE RATE(S)____

EVALUATED BY: L. C. Moore OTHER(S) PRESENT: Terry Carruthers Piedmont Housing

COMMENTS:____

000156