DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET____ OF____

PROPERTY I.D.#:_____
DATE:_____
COUNTY:_____

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Richard Robinson
ADDRESS:_____

OWNER__AGENT:__PHONE:_____
APPLICATION DATE:_____ DATE EVALUATED_____
PROPOSED FACILITY:_____
PROPERTY SIZE:_____

LOCATION OF SITE: Coolwood lot 3
WATER SUPPLY: On-site Well____ Comm. Well___ Public___ Other____ EVAL. METHOD: Auger Boring___ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1		0to4	L	GR				.1942 Wetness Cond. - N/A
		4to48	C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
								.1944 Restrictive Hori. - N/A
	LinD							.1948 Profile Class. - PS
	6							Profile LTAR - .3
2		0to4	L	GR				.1942 Wetness Cond. - N/A
	Linear	4to48	C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
								.1944 Restrictive Hori. - N/A
	6-10							.1948 Profile Class. - PS
								Profile LTAR - .3
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) Yes OTHER FACTORS (.1946)_____ SITECLASSIFICATION (.1948) PS

SYSTEM TYPE Conv. Trench LONG-TERMACCEPTANCE RATE(S) .3

EVALUATED BY: J. C. Moore OTHER(S) PRESENT: Richard Robinson

COMMENTS:_____

00161S