DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Susan Walker OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: Lot 30 Cool Wood
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	linear	0 to 48	C SBK	SEAP FI	PS	PS	PS	PS	.3
2	linear	0 to 48	C SBK	SEAP FI	PS	PS	PS	PS	.3
3	Complex Head Slope	0 to 24	C SBK	SEAP FI	U Chroma 6	U	U	U	<.1
		24 to 48	S ABK	EAP FI					
4									
5									

AVAILABLE SPACE (.1945) PS SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: F. C. VOTHAW PRESENT:
COMMENTS:

002696