DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET ____ OF ____

PROPERTY I.D.#: _____
DATE: _____
COUNTY: _____

SOIL SITE EVALUATION FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Clark Abel
ADDRESS: _____

OWNER ___ AGENT: ___ PHONE: _____
APPLICATION DATE: _____ DATE EVALUATED _____
PROPOSED FACILITY: _____
PROPERTY SIZE: _____

LOCATION OF SITE: _____
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	linear 5-90	0 to 4	L	Gr				.1942 Wetness Cond. - N/A
		4 to 48	C	SBK	Lil			.1943 Depth/.1956 Sapr. - N/A
								.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .3
2	linear 5-90	0 to 4	L	Gr				.1942 Wetness Cond. - N/A
		4 to 48	C	SBK	Lil			.1943 Depth/.1956 Sapr. - N/A
								.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .3
3	linear 6-90	0 to 4	L	Gr				.1942 Wetness Cond. - N/A
		4 to 48	C	SBK	Lil			.1943 Depth/.1956 Sapr. - N/A
								.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .3
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) _____ OTHER FACTORS (.1946) _____ SITE CLASSIFICATION (.1948): PS

SYSTEM TYPE: Conv. Gravity LONG-TERM ACCEPTANCE RATE(S): .3

EVALUATED BY: E.C. Moore OTHER(S) PRESENT: Old Town mtn

COMMENTS: _____