12327

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION 38991

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert L. Scott DATE 5-14-91 PERMIT NO. 114-1-A-80

PHONE: Business _____ Home _____

LOCATION Old Mocksville Hwy TR Whiteoak Branch RJ TL Deer Park ~ 9/10 mile To (R) on (L)


SUBDIVISION NAME Deer Park LOT NO. 80 SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	PS
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	4 GPD / 55' +
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4-6% R-N
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	24'
Lot Area Ample			Rock or other impervious formations	None

_____ Basement with Plumbing _____ Basement without Plumbing (✓) No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Powell Backhoe Svc.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Hedrick

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____

EXISTING SYSTEM CHECKED BY: R. C. Moore DATE 5-14-91

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE _____

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold