HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Wayne Cape OWNER: AGENT: PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 12-13-94
_____ PROPOSED FACILITY: _____
_____ PROPERTY SIZE: 1.7 acres
LOCATION OF SITE: lot 51 Deer Park
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	16% linear	0 to 4"	L	GR		.1942 WETNES CONDITION	N/A
		4 to 36	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		36 to 48	CL	weak SBK	1:1	.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
2	15% linear	0 to 4	L	GR		.1942 WETNES CONDITION	N/A
		4 to 36"	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		36 to 48	CL	weak SBK	1:1	.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
3	12 linear somewhat complex	0 to 8"	L	GR		.1942 WETNESS CONDITION	N/A
		8 to 48	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
						.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) _____ SYSTEM TYPE Conv. Gravity
EVALUATED BY: L.C. Moore OTHER(S) PRESENT: Wayne Cape
COMMENTS: _____

DRAFT