DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Eddie Alspaugh OWNER: _AGENT: _ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
_____ PROPOSED FACILITY: _____
_____ PROPERTY SIZE: _____
LOCATION OF SITE: _____
WATER SUPPLY: On-Site Well____Comm. Well___Public____Other_____EVAL. METHOD: Auger Boring___Pit___Cut___

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY		
1	linear slope 15%	0 to 4"	L	GR		.1942 WETNESS CONDITION	- N/A
		4 to 26	C	SBK	1:1	.1943/.1956 SAPROLITE	- 36"
		26 to 36	Transition			.1944 RESTRICTIVE HORIZON	- Rock 36"
		36"	Rock + Saprolite			.1948 PROFILE CLASSIFICATION	- PS
						PROFILE LTAR	- .35
2	linear 20%	0 to 4	L	GR		.1942 WETNESS CONDITION	- N/A
		4 to 31	C	SBK	1:1	.1943/.1956 SAPROLITE	- 42"
		31 to 36	C	weak SBK	1:1	.1944 RESTRICTIVE HORIZON	- N/A
		36 to 42"	Transition			.1948 PROFILE CLASSIFICATION	- PS
		42+	Saprolite			PROFILE LTAR	- .35
3	linear 10%	0 to 10	L	GR		.1942 WETNESS CONDITION	- N/A
		10 to 36	C	SBK	1:1	.1943/.1956 SAPROLITE	- N/A
		36 to 48	C	weak SBK	1:1	.1944 RESTRICTIVE HORIZON	- N/A
						.1948 PROFILE CLASSIFICATION	- PS
						PROFILE LTAR	- .35
4						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
5						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) _____ SYSTEM TYPE Conv. Gravity
EVALUATED BY: R. C. Proctor OTHER(S) PRESENT: Eddie Alspaugh
COMMENTS: _____

DRAFT