HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 12E-A-260
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: BOBBY G ELMORE OWNER: ✓ AGENT: PHONE: 872-5969
ADDRESS: RT 1 Box 159 APPLICATION DATE: 2/3/99 DATE EVALUATED: 2/3/99
STATESVILLE, NC 28677 PROPOSED FACILITY: 4 BR MH
PROPERTY SIZE: .66 AC
LOCATION OF SITE: US 21 N, TR CHIEF THOMAS RD, ON (L) BEFORE CHADWICK RD
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINERALOGY	
1	~~B~~ L ~~B~~ 2%	0-24	C	SBK	1:1/FR	.1942 WETNESS CONDITION 5
		24-48	C	SBK	1:1/FI	.1943/.1956 SAPROLITE 5
						.1944 RESTRICTIVE HORIZON 5
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.40
2	H 2%	0-24	C	SBK	1:1/FR	.1942 WETNESS CONDITION 5
		24-48	C	SBK	1:1/FI	.1943/.1956 SAPROLITE 5
						.1944 RESTRICTIVE HORIZON 5
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.40
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILL CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.40 GPD/FT2
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY // ABPS REPAIR
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: HOMER BALL
COMMENTS:

DRAFT