DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: PENDER

4778 07 5060 (PI)

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: RONALD RICHARD ROCHE APPLICANT: _____
ADDRESS: 1816 ~~BELVOIR~~ RD, RH, SC. APPLICATION DATE: _____ DATE EVALUATED: 3.15.99
PROPOSED FACILITY: 3BR S/W PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.13 ACRES
LOCATION OF SITE: EASTON ACRES #29 PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger ~~Boring~~ ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	N 6%	0-48	SBK / C	FI-SP / SEXP					PS 0.35
2	N 7%	0-48	SBK / C	FI-SP / SEXP					PS 0.35
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	~~YES~~ S	S
System Type(s)	I	II
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: _____