DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of _
PROPERTY ID #: 4778 17 5548
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: JAVIER ROMERO APPLICANT:
ADDRESS: 552 COOL SPRINGS RD, STVL, NC APPLICATION DATE: 3-25-99 DATE EVALUATED: 4-8-99
PROPOSED FACILITY: 3BR S/W MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.06 ACRES
LOCATION OF SITE: EASTERN ACRES #6 PROPERTY RECORDED:
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	L 6%	0-36	SBK / C	FI / SEXP					PS 0.3
		36-48	SBK / SC	FR / SEXP					
2	L 4%	0-34	SBK / C	FI / SEXP					PS 0.3
		34-48	SBK / SC	FR / SEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	III
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: TERRY SIMMONS