DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ of _____
PROPERTY ID #: _____
COUNTY: [redacted]

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

#778 79 4377 (PT)

OWNER: ANDY BROWN APPLICANT: BOB HADEN
ADDRESS: PO Box 1651 STVL NC 28687 APPLICATION DATE: _____ DATE EVALUATED: 3-16-00
PROPOSED FACILITY: 4BR D/W MH PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: 1.58 acres
LOCATION OF SITE: ROCK GATE # 45 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 8% PT	0-8	GR SCL	VFR / NE-NP					PS 0.3
		8-48	MMSBK / CL	FR SS/SP/SEXP					
2	L 10% PT	0-10	GR / SCL	VFR / NEXP			PS		PS 0.3
		10-42	MMSBK / CL	FR SS/SP/SEXP					
		42-48	SBK / CL SPMX	VFR SS/SP/SEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	IV	IV
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HORNE
OTHER(S) PRESENT: BOB HADEN