35179

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

10182

OWNER OR CONTRACTOR Gerard Faughnan DATE 9/1/89 PERMIT NO. 12E-1-A-90

PHONE: Business Home

LOCATION 21N R Mt Bethel L Mt Bethel Park L Mt on left at Culde Sac S. R. No.


SUBDIVISION NAME Mt Bethel LOT NO. 90 SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2	No. Bathrooms 2		Character & Porosity of Soil Gravelly Loam
Garbage Disposal Unit	Yes ( )	No (✓)	Percolation Rate 30 Min/Inch
Auto. Dishwasher	Yes ( )	No (✓)	Topography Level
Auto. Wash. Machine	Yes (✓)	No ( )	Depth to Water Table Deep
Site Suitable	Yes (✓)	No ( )	Rock or other impervious formations None

Lot Area 1.49 ± Acres

____ Basement with Plumbing ____ Basement without Plumbing (✓) No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 300 Linear Ft. 240

Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Tommy Frye

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY D Weaver

COMMENTS: Filled well identified by Gerard Faughnan

DATE _____

CERTIFICATE OF COMPLETION BY D Weaver DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold