HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 12E-1-A-35
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: ERNEST J. WILES OWNER: ~~AGENT~~: PHONE: 546-5261
ADDRESS: Rt. 1, Box C-122 APPLICATION DATE: 2/18/94 DATE EVALUATED: 2/18/94
HARMONY, NC 28634 PROPOSED FACILITY: 3BR D/W MH
PROPERTY SIZE: ~ 150' x 223'
LOCATION OF SITE: US 21 N, TR BETHEL, TL MARGARET TL LINDA 1ST LOT on (R)
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 6%	0-20	C	SBK	1:1 / FI	.1942 WETNES CONDITION S
		20-48	C	SBK	1:1 / FR	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35
2	H 8%	0-18	C	ABK	1:1 / FI	.1942 WETNES CONDITION S
		18-48	C	SBK	1:1 / FR	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35
3	H 6%	0-22	C	SBK	1:1 / FI	.1942 WETNESS CONDITION S
		22-48	SC	SBK	1:1 / FR	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: ERNEST WILES, WIFE & CHILDREN
COMMENTS:

DRAFT