12063

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION 39538

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Wayne L. Hill DATE 5-7-91 PERMIT NO. 12E-1-A-15

PHONE: Business _____ Home 843 0606

LOCATION US 21 N Tr Bethel Rd Tr Bethel Pk. At ent opposite T Jct. S. R. No. _____

SUBDIVISION NAME Bethel Park LOT NO. 15 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil PS
Percolation Rate 4
Topography 6 to 10
Depth to Water Table > 4'
Rock or other impervious formations None

Lot Area ~ 1 acre

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System Street

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Sammy Reavis

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Hetrick

COMMENTS: _____

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 5-2-97

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold