IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J. W. Parks DATE 4 Dec 73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21N - 4/10 past Tobe Ln Rd on left. Owen Creek - up & top of hill - Trailer on right. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes ( )	No (✓)	
Site Suitable	Yes (✓)	No ( )	

Lot Area 3 acres


Character & Porosity of Soil Red Clay Loam

Percolation Rate more

Topography Steep

Depth to Water Table not

Rock or other impervious formations sandstone



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 562½ Linear Ft. 225
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Owen Abernathy

IMPROVEMENTS PERMIT BY _____

COMMENTS: Trailer on steep hill. Tank on hill. Drain at bottom on gently sloping land.

CERTIFICATE OF COMPLETION BY William M. Stewart DATE 4 Dec 73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold