IREDELL COUNTY HEALTH DEPARTMENT

11854 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR WILLIE DALTON DATE 3/14/90 PERMIT NO. 124-A-97A

PHONE: Business _____ Home _____

LOCATION 115 21 N. TR BETHEL CH. RD TRADDLEBROOK ON (L) NEAR END. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 1.0 Ac

Character & Porosity of Soil 4 1000 CLAYEY
Percolation Rate 4-60 54
Topography
Depth to Water Table
Rock or other impervious formations SCATTERED

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓) SHARED
Public ( )

Installed by DENNIS GALLAGHER

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HENDRICK / J. C. MOORE

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HENDRICK / GLENN FOX, JR DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold